

EU type examination certificate
EU-Baumusterprüfbescheinigung


CE-0085DN0121
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers: Condensing water heater (3102)
Product Description <i>Produktbezeichnung</i>	floor standing gas fired central heating condensing boiler
Model <i>Modell</i>	LAMBORGHINI CALORECLIMA TITAN ...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: K 2975 2022 E4 from 06.07.2022 (TRG) supplement test: K 2975 2022 B6 from 06.07.2022 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	22.03.2032 / 22-0360-GEA



70029-04-A-DE

11.11.2022 Pz B-1/2



Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
 Zertifizierungsstelle
 Josef-Wirmer-Str. 1-3
 53123 Bonn
 Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993
 www.dvgw-cert.com
 info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz
Elektrische Daten

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2H	20 mbar	DK, EE, FI, NO, SE, TR	
I2HS	25 mbar	HU	
II2E(S)3P	20, 37 mbar	BE	
II2E3P	13, 37 mbar	PL	
II2E3P	20, 37 mbar	PL	
II2EK3P	20/25, 30 mbar	NL	
II2EK3P	20/25, 37 mbar	NL	
II2EK3P	20/25, 50 mbar	NL	
II2ELL3P	20, 50 mbar	DE	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	CZ, IS, LU, LV, RO	
II2H3P	20, 37 mbar	CH, CZ, ES, FR, GB, GR, HR, IE, IS, IT, LT, LU, LV, PT, SI, SK	
II2H3P	20, 50 mbar	AT, CH, IS, LU, LV, SK	
II2HM3P	20, 37 mbar	IT	

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	AL, AT, BE, BG, CH, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
LAMBORGHINI	nominal heat output: 13,7...139,2 kW	
CALORECLIMA TITAN 150	heat input (Hi): 14,0...142,0 kW	
LAMBORGHINI	nominal heat output: 13,7...208,8 kW	
CALORECLIMA TITAN 225	heat input (Hi): 14,0...213,0 kW	
LAMBORGHINI	nominal heat output: 13,7...278,4 kW	
CALORECLIMA TITAN 300	heat input (Hi): 14,0...284,0 kW	
LAMBORGHINI	nominal heat output: 13,7...348,1 kW	
CALORECLIMA TITAN 370	heat input (Hi): 14,0...355,0 kW	
LAMBORGHINI	nominal heat output: 13,7...417,7 kW	
CALORECLIMA TITAN 450	heat input (Hi): 14,0...426,0 kW	
LAMBORGHINI	nominal heat output: 13,7...487,3 kW	
CALORECLIMA TITAN 520	heat input (Hi): 14,0...497,0 kW	
LAMBORGHINI	nominal heat output: 13,7...556,9 kW	
CALORECLIMA TITAN 600	heat input (Hi): 14,0...568,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Additionally tested appliance categories, supply pressures and countries of destination:

GB; II2H3P (20, 30 mbar)

AL, BG, MK, MT: II2H3P (20, 30 mbar)

AL, BG, MK, MT: II2H3P (20, 37 mbar)

AL, BG, MK, MT: II2H3P (20, 50 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

The recognition of the CE mark in the United Kingdom is currently limited to January 1st, 2023.

DWG