

C € 0085



CERT

## EU type examination certificate

### EU-Baumusterprüfbescheinigung

CE-0085CU0319

Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
<b>Distributor</b> <i>Vertreiber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
<b>Product description</b> <i>Produktbezeichnung</i>	Wall hanging condensing boiler with integrated burner in modulating operation method and with enclosed combustion chamber
<b>Model</b> <i>Modell</i>	LAMBORGHINI CALORECLIMA IXINOX JET 24C; LAMBORGHINI CALORECLIMA ALHENA...
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
<b>Test reports</b> <i>Prüfberichte</i>	Supplement test: K 2567 2023 E19 from 14.11.2023 (TRG) Supplement test: K 2567 2023 B21 from 14.11.2023 (TRG)
<b>Test basis</b> <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.08.2024) DIN EN 15502-2-1 (01.08.2024) DVGW CERT ZP 3100-20 (12.03.2024)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / AZ</i>	28.10.2029 / 24-0396-GER



22.01.2025 Cat B-1/2

*J. A. W. T. C.*

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - notified by the government of the Federal Republic of Germany and officially registered by the European Commission for conformity assessment of gas appliances

DVGW CERT GmbH – von der Deutschen Bundesregierung benannte und von der Europäischen Kommission offiziell registrierte Stelle für die Konformitätsbewertung von Gasgeräten

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com



**Elektrical Data**  
*Elektrische Daten*

230 V AC, 50 Hz

Appliance Categories <i>Geräte Kategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E	20 mbar	LU, RO	
I2H	20 mbar	CZ, ES, FR, GR	
I2H	25 mbar	NL	
I3B	30 mbar	ES, IE	
I3B	37 mbar	ES, IE	
I3B/P	30 mbar	BE, PT	
I3B/P	37 mbar	BE, PT	
I3B/P	50 mbar	DE, GR	
II2E+3+	20/25, 28-30/37 mbar	BE, FR	
II2E+3B/P	20/25, 37 mbar	FR	
II2E+3P	20/25, 30 mbar	BE	
II2E+3P	20/25, 37 mbar	BE	
II2E3B/P	20, 50 mbar	DE	
II2E3B/P	20, 30 mbar	PL	
II2EK3B/P	25, 30 mbar	NL	
II2ELL3B/P	20, 50 mbar	DE	
II2ELw3B/P	20, 30 mbar	PL	
II2H3+	20, 28-30/37 mbar	CH, CY, CZ, ES, GB, GR, IE, IT, LT, PT, SI, SK	
II2H3+	20, 30/37 mbar	TR	
II2H3B/P	20, 30 mbar	CY, CZ, DK, EE, FI, HR, HU, IS, IT, LT, NO, RO, SE, SI, SK	
II2H3B/P	20, 37 mbar	HR, IT, LV, TR	
II2H3B/P	20, 50 mbar	AT, CH, GR, LU, SK	
II2H3P	20, 30 mbar	ES, IE, PT	
II2H3P	20, 37 mbar	ES, GB, IE, PT	
II2HM3+	20, 28-30/37 mbar	IT	
II2HM3B/P	20, 30 mbar	IT	
II2HM3B/P	20, 37 mbar	IT	
II2HM3P	20, 30 mbar	IT	
II2HM3P	20, 37 mbar	IT	
II2HS3B/P	25, 30 mbar	HU	
II2L3B/P	25, 30 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
LAMBORGHINI CALORECLIMA IXINOX JET 24C; LAMBORGHINI CALORECLIMA ALHENA 24C	Nominal heat output: 4,1...20,0 kW Heat input (Hi): 4,2...20,6 (drinking water: ...25,0) kW	
LAMBORGHINI CALORECLIMA ALHENA 28C	Nominal heat output: 4,7...27,8 kW Heat input (Hi): 4,8...28,5 (drinking water: ...28,5) kW	
LAMBORGHINI CALORECLIMA ALHENA 34C	Nominal heat output: 4,8...34,0 kW Heat input (Hi): 5,0...34,8 (drinking water: ...34,8) kW	

**Hints of Utilization /Remarks**
**Verwendungshinweise / Bemerkungen**

flue types B23, B33, C10, C11, C13, C23, C33, C43, C53, C63, C83, C93: according to installation manual  
LAMBORGHINI... with flue system of Groppalli (approval no. 2592-CPR-0001)

Additionally tested appliance categories, supply pressures and countries of destination:

AL, MK: II2E3B/P (20, 50 mbar)

BG, MT: II2H3B/P (20, 30 mbar)

ES, FR, GR, PT, SI: I2N (20 mbar)

BE: I2N (20/25 mbar)

The boilers are qualified for the addition of up to 20 vol.-% hydrogen to natural gas (G20) as burning gas according to DVGW CERT ZP 3100-20.

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.